



QUALITY CONTROL SUB DISTRICT LAB  
KERALA WATER AUTHORITY  
COLLECTORATE P O, KOTTAYAM  
Telephone No. 0481 2302391, Email- qcsdlktm@gmail.com

TEST REPORT

Report No:862/QC/KTM/06/2023	Date: 22.06.2023
------------------------------	------------------

Customer Name & Address <b>Lizzy Sunny Stephen</b> <b>St.Sebatian Public School</b> <b>Peroor.P.O. Kottayam</b>	1.Date of Receipt	19.06.2023
	2.Sampling done by	Customer
	3.Sample Code	2023/QC/KTM/M2990
	4.Source of Sample	Open Well
	5.Sample Quantity	100ML
	6.Sample Condition	Acceptable
	7.Test performing dates: 19.06.2023 – 22.06.2023	

BACTERIOLOGICAL ANALYSIS

Sl No.	Parameters	Acceptable limits as per – IS 10500-2012	Test Method	Result
1	Coliforms	Shall not be detected/100ml	MPN METHOD	Nil
2	E.coli	Shall not be detected/100ml	MPN METHOD	Nil

**Remarks: -**

NB:- The result stated above related only to the sample(s)submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

- \*Samples will be retained only for 7 days after completion of analysis
- \*Sampling is not done by the Lab

\*END OF REPORT\*



*[Signature]*  
22/6/23  
Authorized By  
*[Signature]*  
Shaswara R. Chuback